



Intertek Testing Services



1. EC TYPE-EXAMINATION CERTIFICATE

2. Equipment or Protective System Intended for use in Potentially Explosive Atmospheres Directive 94/9/EC

3. EC-Type Examination Certificate Number: ITS01ATEX2001

4. Equipment or Protective System: BA334D EXTERNALLY POWERED RATE TOTALISER

5. Manufacturer: BEKA ASSOCIATES LIMITED

6. Address: Old Charlton Road, Hitchin, Herts, SG5 2DA

7. This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8. The ITS Testing and Certification Limited, notified body number 0359 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report Number:
ITS Report Ref 00001155, dated April 2001

9. Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
EN 50014: 1992, EN 50020: 1994
except in respect of those requirements listed at item 18 of the Schedule.

10. If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

11. This EC-TYPE EXAMINATION CERTIFICATE relates only to the design of the specified equipment or protective system. Further requirements of this Directive apply to the manufacture and supply of this equipment or protection system.

12. The marking of the equipment or protective system shall include the following:-



II 1 G, EEx ia IIC T5 (Tamb= -40°C to 60°C)

R M Adams
Quality Manager
18 May 2001

ITS Testing & Certification Limited
ITS House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900 Fax: +44 (0)1372 370977
<http://www.itsglobal.com>
Registered No 3272281 Registered Office: 25 Savile Row London W1X 1AA

This certificate may only be reproduced in its entirety and without any change, schedule included.

ITS Intertek Testing Services

13. Schedule

14. EC-TYPE EXAMINATION CERTIFICATE NUMBER ITS01ATEX2001

15. Description of Equipment or Protective System.

BA334D Externally Powered Rate Totaliser is field mounting equipment externally powered pulse input rate totalisers primarily intended for use with flowmeters and provide a display in engineering units.

The BA334D may additionally be fitted with optional external keypad, Alarm Interface board, Backlight board, 4-20mA Sub-board and/or Retrasmited Pulse circuit.

The BA334D comprises a terminal board, a display board and optional external keypad, Alarm Interface board, a Backlight board and/or a 4-20 mA Sub-board all housed within a metallic or a plastic enclosure. The enclosure provides a Degree of Protection of at least IP20.

Intrinsic safety is assured by limitation of voltage, current and power, limitation of capacitance, limitation of inductance and infallible segregation.

The maximum intrinsically safe input parameters are as follows:

Power supply terminals 1 and 2

$U_i = 28 \text{ V dc}$

$I_i = 100 \text{ mA dc}$

$P_i = 0.7 \text{ W}$

The equivalent parameters are:

$C_i = 0.02 \text{ } \mu\text{F}$

$L_i = 0.02 \text{ mH}$

ITS Testing & Certification Limited
ITS House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900 Fax: +44 (0)1372 370977

<http://www.itsglobal.com>

Registered No 3272281 Registered Office: 25 Savile Row London W1X 1AA

This Certificate is the property of ITS Testing and Certification Ltd
and is subject to ITS Testing and Certification Conditions for Granting Certification .

13. **Schedule**

14. EC-TYPE EXAMINATION CERTIFICATE NUMBER ITS01ATEX2001

Pulse input terminals 3 and 4

$U_i = 28 \text{ V dc}$
 $I_i = 100 \text{ mA dc}$
 $P_i = 0.7 \text{ W}$

$U_o = 1.1 \text{ V dc}$
 $I_o = 0.5 \text{ mA dc}$
 $P_o = 0.2 \text{ mW}$

The equivalent parameters are:

$C_i = 0.02 \text{ }\mu\text{F}$
 $L_i = 0.02 \text{ mH}$

Pulse input terminals 5 and 6

$U_i = 28 \text{ V dc}$
 $I_i = 100 \text{ mA dc}$
 $P_i = 0.7 \text{ W}$

$U_o = 10.5 \text{ V dc}$
 $I_o = 9.2 \text{ mA dc}$
 $P_o = 24 \text{ mW}$

The equivalent parameters are:

$C_i = 0.02 \text{ }\mu\text{F}$
 $L_i = 0.02 \text{ mH}$

Reset terminals 7 and 8

$U_i = 28 \text{ V dc}$
 $I_i = 100 \text{ mA dc}$
 $P_i = 0.7 \text{ W}$

$U_o = 3.8 \text{ V dc}$
 $I_o = 1.6 \text{ mA dc}$
 $P_o = 2.0 \text{ mW}$

The equivalent parameters are:

$C_i = 0.02 \text{ }\mu\text{F}$
 $L_i = 0 \text{ mH}$

Backlight terminals B1 and B2

$U_i = 28 \text{ V dc}$
 $I_i = 159 \text{ mA dc}$
 $P_i = 0.8 \text{ W}$

The equivalent parameters are:

$C_i = 0.04 \text{ }\mu\text{F}$
 $L_i = 0.03 \text{ mH}$

ITS Testing & Certification Limited
ITS House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900 Fax: +44 (0)1372 370977
<http://www.itsglobal.com>

Registered No 3272281 Registered Office: 25 Savile Row London W1X 1AA

This Certificate is the property of ITS Testing and Certification Ltd
and is subject to ITS Testing and Certification Conditions for Granting Certification .



Intertek Testing Services

13. **Schedule**
14. EC-TYPE EXAMINATION CERTIFICATE NUMBER ITS01ATEX2001

Alarm terminals A1 and A2; A3 and A4

$U_i = 28 \text{ V dc}$	$U_o = 0.7 \text{ V dc}$
$I_i = 200 \text{ mA dc}$	$I_o = 1.3 \mu\text{A}$
$P_i = 0.85 \text{ W}$	$P_o = 4.1 \mu\text{W}$

The equivalent parameters are:

$C_i = 0.04 \mu\text{F}$
 $L_i = 0.03 \text{ mH}$

Pulse output terminals P1 and P2

$U_i = 28 \text{ V dc}$	$U_o = 0$
$I_i = 100 \text{ mA dc}$	$I_o = 0$
$P_i = 0.7 \text{ W}$	

The equivalent parameters are:

$C_i = 0.02 \mu\text{F}$
 $L_i = 0.02 \text{ mH}$

4-20 mA output terminals C1 and C2

$U_i = 28 \text{ V dc}$	$U_o = 0$
$I_i = 100 \text{ mA dc}$	$I_o = 0$
$P_i = 0.7 \text{ W}$	

The equivalent parameters are:

$C_i = 0.002 \mu\text{F}$
 $L_i = 0.008 \text{ mH}$

For intrinsic safety considerations, under fault conditions the voltage, current and power at terminals 3 and 4, A1 and A2, and A3 and A4 do not exceed those specified in Clause 5.4 of EN 50020: 1994. The equivalent capacitance and inductance are the result of r.f suppression components directly connected to the apparatus terminals.

16. Report No. ITS Report Ref 00001155.
17. SPECIAL CONDITIONS FOR SAFE USE
None

ITS Testing & Certification Limited
ITS House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900 Fax: +44 (0)1372 370977
<http://www.itsglobal.com>
Registered No 3272281 Registered Office: 25 Savile Row London W1X 1AA

This Certificate is the property of ITS Testing and Certification Ltd
and is subject to ITS Testing and Certification Conditions for Granting Certification.

13. **Schedule**

14. EC-TYPE EXAMINATION CERTIFICATE NUMBER ITS01ATEX2001

18. Essential Health and Safety Requirements

Essential Health and Safety Requirements not covered by Standards listed at (9)		
Clause	Subject	Compliance
1.01	Principal of integrated explosion protection	The equipment is designed to comply with the requirements of EN 50014 and EN 50020
1.02	Analysis of possible operating faults	The equipment is designed to comply with failure modes specified in EN 50020
1.0.3	Special checking and maintenance conditions	No special requirements
1.0.6	Instructions	Instruction Manual provides all the information
1.2.1	Design with regard to technical knowledge	The state of the art as specified in EN 50014 and EN 50020 satisfies this requirement
1.2.4	Dust deposits	Certification for gas atmospheres only
1.2.5	Additional means of protection	No special requirements
1.2.7	Protection against other hazards	The equipment is designed to comply with the requirements of EN 50014
1.6.4	Hazards arising from connections	The equipment is provided with suitable conduit entries
2.1.1	Explosive atmospheres caused by gases, vapours or hazes.	Equipment is designed to comply with the requirements of EN 50020

19. **DRAWINGS**

Number	Issue	Date	Description
CI330-16 sheets 1 to 27	1	Oct 00	BA334D, BA338C, BA364D and BA368C Certification Information

ITS Testing & Certification Limited
 ITS House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
 Tel: + 44 (0)1372 370900 Fax: +44 (0)1372 370977
<http://www.itsglobal.com>
 Registered No 3272281 Registered Office: 25 Savile Row London W1X 1AA

This Certificate is the property of ITS Testing and Certification Ltd
 and is subject to ITS Testing and Certification Conditions for Granting Certification .



Intertek Testing Services



1. **SUPPLEMENTARY EC-TYPE EXAMINATION CERTIFICATE**

2. **Equipment or Protective System Intended for use in
Potentially Explosive Atmospheres Directive 94/9/EC**

3. Supplementary EC-Type Examination Certificate Number: **ITS01ATEX2001/1**

4. Equipment or Protective System: **BA334D EXTERNALLY POWERED RATE
TOTALISER**

5. Manufacturer: **BEKA ASSOCIATES LIMITED**

6. Address: **Old Charlton Road, Hitchin, Herts, SG5 2DA**

7. This supplementary certificate extends EC-Type Examination Certificate Number ITS01ATEX2001 to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said Certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

ITS Project Number 02007375.

This Supplementary Certificate shall be held with the original Certificate

**R M Adams
Deputy Certification Manager**

7th May 2002

ITS Testing & Certification Limited
ITS House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0) 1372 370900 Fax: +44 (0) 1372 370977
<http://www.etlsemko.com/uk>
Registered No 3272281 Registered Office: 25 Savile Row London W1X 1AA

This Certificate is the property of ITS Testing and Certification Ltd
and is subject to ITS Testing and Certification Conditions for Granting Certification.

Schedule

SUPPLEMENTARY EC-TYPE EXAMINATION CERTIFICATE NUMBER ITS01ATEX2001/1

VARIATION ONE

Description of the Variation to the Equipment or Protective System.

To permit the addition of R410 on PC100. This change does not affect Intrinsic Safety

Report Nos.

None

SPECIAL CONDITIONS FOR SAFE USE

None

Essential Health and Safety Requirements

See original certificate

DRAWINGS

Number	Issue	Date	Description
CI330-16 Sheets 2, 13 and 23	2	April. 02	BA334D, BA338C, BA364D and BA368C Certification Information

ITS Testing & Certification Limited
ITS House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0) 1372 370900 Fax: +44 (0) 1372 370977
<http://www.etlsemko.com/uk>
Registered No 3272281 Registered Office: 25 Savile Row London W1X 1AA

This Certificate is the property of ITS Testing and Certification Ltd
and is subject to ITS Testing and Certification Conditions for Granting Certification.



Intertek ETL SEMKO

1. **SUPPLEMENTARY EC-TYPE EXAMINATION CERTIFICATE**
2. **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres Directive 94/9/EC**
3. Supplementary EC-Type Examination Certificate Number: **ITS01ATEX2001/2**
4. Equipment or Protective System: **BA334D EXTERNALLY POWERED RATE TOTALISER**
5. Manufacturer: **BEKA ASSOCIATES LIMITED**
6. Address: **Old Charlton Road, Hitchin, Herts, SG5 2DA**
7. This supplementary certificate extends EC-Type Examination Certificate Number ITS01ATEX2001 to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said Certificate but having variations specified in the Schedule attached to this certificate and the documents therein referred to.

Intertek Ref 04013097

This Supplementary Certificate shall be held with the original Certificate

T Cuthbert
Deputy Certification Manager
24 March 2004

Intertek Testing & Certification Limited
Intertek House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0) 1372 370900 Fax: +44 (0) 1372 370977
<http://www.uk.intertek-etlsemko.com>
Registered No 3272281 Registered Office: 25 Savile Row London W1X 1AA

This Certificate is the property of Intertek Testing and Certification Ltd
and is subject to Intertek Testing and Certification Conditions for Granting Certification.

Intertek ETL SEMKO

Schedule

SUPPLEMENTARY EC-TYPE EXAMINATION CERTIFICATE NUMBER ITS01ATEX2001/2

VARIATION TWO

Description of the Variation to the Equipment or Protective System.

To permit the following changes:

- a) Deletion of material specification from GRP enclosure.
- b) Introduction of membrane switch with surface resistance of less than $10^9 \Omega$.

The above changes do not impair intrinsic safety.

Report No.

Intertek Ref 04013097

SPECIAL CONDITIONS FOR SAFE USE

None

Essential Health and Safety Requirements

See original certificate

DRAWINGS

Number	Issue	Date	Description
CI330-16, sheets 2 & 24	3	Nov 03	BA334D, BA338C, BA364D and BA368C Certification Information

Intertek Testing & Certification Limited
Intertek House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0) 1372 370900 Fax: +44 (0) 1372 370977
<http://www.uk.intertek-etlsemko.com>
Registered No 3272281 Registered Office: 25 Savile Row London W1X 1AA

This Certificate is the property of Intertek Testing and Certification Ltd
and is subject to Intertek Testing and Certification Conditions for Granting Certification.



Intertek Industrial

1. **SUPPLEMENTARY EC-TYPE EXAMINATION CERTIFICATE**
2. **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres Directive 94/9/EC**
3. Supplementary EC-Type Examination Certificate Number: **ITS01ATEX2001/3**
4. Equipment or Protective System: **BA334D EXTERNALLY POWERED RATE TOTALISER**
5. Manufacturer: **BEKA ASSOCIATES LIMITED**
6. Address: **Old Charlton Road, Hitchin, Herts, SG5 2DA**
7. This supplementary certificate extends EC-Type Examination Certificate Number ITS01ATEX2001 to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said Certificate but having variations specified in the Schedule attached to this certificate and the documents therein referred to.

Intertek Ref 04014720

This Supplementary Certificate shall be held with the original Certificate

A T Austin
Head of Department
22 June 2006

Intertek Testing & Certification Limited
Intertek House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0) 1372 370900 Fax: +44 (0) 1372 370977
<http://www.uk.intertek-etlsemko.com>
Registered No 3272281 Registered Office: 25 Savile Row London W1X 1AA

This Certificate is the property of Intertek Testing and Certification Ltd and is subject to Intertek Testing and Certification Conditions for Granting Certification.

Sheet 1 of 2

This certificate, originally dated 30 November 2004, has been re-issued to correct the Variation Number to Three.

Intertek Industrial

Schedule

SUPPLEMENTARY EC-TYPE EXAMINATION CERTIFICATE NUMBER ITS01ATEX2001/3

VARIATION THREE

Description of the Variation to the Equipment or Protective System.

To permit the following changes:

- a) Minor mechanical modifications to the apparatus enclosure to enable it for use in the presence of combustible dust. The enclosure provides a degree of protection IP66

The codes are: Ⓢ II 1 G, EEx ia IIC T5 (Tamb= -40°C to 60°C)
Ⓢ II 1 GD, EEx ia IIC T5 (Tamb= -20°C to 60°C)
- b) Alternative method of printing the label- laser marked onto aluminium label or thermally printed onto polyester label with acrylic self-adhesive backing.

The above changes do not impair intrinsic safety.

Report No.

Intertek Ref 04014720

SPECIAL CONDITIONS FOR SAFE USE

None

Essential Health and Safety Requirements

See original certificate

DRAWINGS

Number	Issue	Date	Description
CI330-16, sheets 2, 24, 27	4	July 04	BA334D, BA338C, BA364D and BA368C Certification Information

The above drawings are common to Certificate No ITS01ATEX2003/3

Intertek Testing & Certification Limited
Intertek House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0) 1372 370900 Fax: +44 (0) 1372 370977
<http://www.uk.intertek-etlsemko.com>
Registered No 3272281 Registered Office: 25 Saville Row London W1X 1AA

This Certificate is the property of Intertek Testing and Certification Ltd
and is subject to Intertek Testing and Certification Conditions for Granting Certification.