



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

BR323ALN, BR323ALM, BR323SSN, BR323SSM. Field Mounting Indicator.

XP/II/1/ABCD/T6Ta = 60°C; T5 Ta = 85°C; DIP/II,III/1/EFG/T6Ta = 60°C; T5 Ta = 85°C; Type 4X, IP66

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups A, B, C and D; Dust-Ignitionproof for Class II/III, Division 1 Groups E, F, and G, Hazardous (Classified) Locations, indoors and outdoors rated NEMA Type 4X and IP66.

FM Approved for:

BEKA Associates Ltd.
Hitchin, Hertfordshire, United Kingdom



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3615	1989
Class 3810	1989
(Includes Supplement 1)	1995
ANSI/NEMA 250	1991
IEC-60529	1989
(Includes Amendment 1)	1999

Original Project ID: 3031755

Approval Granted: *December 17, 2007*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC



Andrew Lozinski
Technical Team Manager

2 January 2008
Date